



TOWARDS A SMART &
INTEGRAL TREATMENT OF
NATURAL RADIOACTIVITY
IN WATER PROVISION
SERVICES

ALCHEMIA Preliminary Spanish results

***J.L. Casas López^{1,2}, G. Pinna Hernández^{1,2}, I. Rodríguez Ruano³,
F. J. Martínez Rodríguez³***

- (1) Solar Energy Research Centre (CIESOL), University of Almería, Almería, Spain. jlcasas@ual.es
- (2) Chemical Engineering Department. University of Almería, Spain.
- (3) Diputación Provincial de Almería, Almería, Spain.

CIESOL, Solar Energy Research Center

CIESOL was created in 2005, is a joint research center, between the University of Almeria and the Center for Energy, Environment and Technology (CIEMAT) attached to the Ministry of Science, Innovation and Universities.



Interdisciplinarity:

Physicists, chemists, biologists and industrial engineers.

Aimed to various industrial sectors:

- Medium and high temperature solar thermal energy
- Design and optimization of solar thermal cooling and heating systems
- **Water treatment (desalination, purification, microalgae)**
- Integration of the solar thermal and photovoltaic energy in buildings



INDEX

Project Introduction and objectives
Demos location and raw water analysis
Spanish demos description
Results
Water & filter materials
Water & Energy consumption
Conclusions and future works



LIFE ALCHEMIA

Towards a smart & integral treatment of natural radioactivity in water provision services



European Union programme LIFE Project (LIFE16 ENV/ES/000437)

www.lifealchemy.eu

WATER INTAKE
DRILLING



Main objectives of the Project

- ✓ Remove the **natural** occurring radioactivity from water for human consumption with the use of sustainable systems based on the manganese dioxide oxidation and filtration
- ✓ Minimize the generation of Naturally Occurring Radioactive Materials (NORM) in these treatments
- ✓ Replicate the solutions developed by the LIFE ALCHEMIA Project in the other European countries

**Life ALCHEMIA
Pilot Plant**

- 1 pilot plant in the Viimsi Parish (Estonia)
- 3 pilot plants in the province of Almería (Spain)



DRINKING WATER
TREATMENT
PLANT



DRINKING WATER

Spanish demos locations and raw water analysis

ALCHEMIA PLANTS LOCATIONS



Tahal pilot plant




Benizalón pilot plant



Alboloduy pilot plant

WATER TREATMENT PLANTS SITUATION

PILOT PLANTS ALCHEMIA



ALBOLODUY

Analytical report on radiological characterization of water from the 3 WWTPs of Alboloduy, Benizalón and Tahal

In all cases gross alpha exceed the limits and the ID were calculated

Radionuclide	Activity (Bq/L)	% TID
²³⁴ U	0.218±0.031	35,46%
²³⁵ U	0.021±0.005	
²³⁸ U	0.239±0.034	35,70%
²²⁶ Ra	0,0035	
²²⁸ Ra	<0.020	
²¹⁰ Po	<0.001	
²¹⁰ Pb	0.008	18,32%
ID	0.0220 mSv/y	

Main concentrations

	U	Ra	Pb	Po
Alboloduy	74,4%	3,3%	18,3%	4,0%
Benizalón	57,9%	30,9%	8,0%	4,0%
Tahal	25,6%	59,7%	15,3%	3,1%

BENIZALÓN

TAHAL


Radionuclide	Activity (Bq/L)	% TID
²³⁴ U	3.43±0.42	34,69%
²³⁵ U	0.090±0.013	
²³⁸ U	2.40±0.29	22,29%
²²⁶ Ra	0.195±0.017	
²²⁸ Ra	0.133±0.013	18,94%
²¹⁰ Po	0.016±0.003	
²¹⁰ Pb	0.056	
ID	0.3537 mSv/y	

Radionuclide	Activity (Bq/L)	% TID
²³⁴ U	0.392±0.043	16,43%
²³⁵ U	0.010±0.002	
²³⁸ U	0.229±0.026	
²²⁶ Ra	0.061±0.004	
²²⁸ Ra	0.070±0.009	41,32%
²¹⁰ Po	0.0030±0.0005	
²¹⁰ Pb	0.026	15,35%
ID	0.0853 mSv/y	

*Several wells
in each
location
makes*

Spanish plants description


FILTRATION CYCLE



**FILTRATION UNDER
PRESSURE**

NOMINAL FLOW 10 m³/h

BACKWASHING CYCLE




BACKWASH UNDER PRESSURE

NOMINAL FLOW 20 m³/h

Alchemia plants description

- ❑ Small town with 621 registered inhabitants in 2018
- ❑ Clean water reservoir for backwash
- ❑ Raw water tank ensure flow stability
- ❑ Filtration and backwash with pumps
- ❑ Raw water tank provided of aeration
- ❑ Plant provided of reagents dosing pumps to control pH and ORP


ALBOLODUY



Alchemia plants description

- ❑ Small town with 263 registered inhabitants in 2017
- ❑ No clean water reservoir for backwash due to several logistic reasons
- ❑ Raw water tank to ensure flow stability
- ❑ Filtration and backwash with pumps
- ❑ Backwash with raw water
- ❑ Important water restrictions during summer
- ❑ Raw water tank provided of aeration
- ❑ Plant provided of reagents dosing pumps to control pH and ORP


BENIZALÓN



Alchemia plants description

- ❑ Small town of 346 registered inhabitants in 2017
- ❑ Wells 100 m higher than the plant location.
- ❑ Filtration operation can be carried out without pump.
- ❑ Reservoir clean water for backwashing
- ❑ Backwash with clean water
- ❑ Plant provided of reagents dosing pumps to control pH and ORP

TAHAL



Selecting the catalyst filter media

- **Alboloduy**: the main isotopes behind the ID is U234 and U238 (74,4%)



First filter: **Katalox light**, good efficiency to eliminate Ra and U



Second filter: **Zeosorb** has been proved to efficiently remove Ra from water and be a good ion exchanger.

- **Benizalon**: the physico-chemical parameters comply with Spanish Law and the radiological characteristics of this water are the most complex, since the ID (0.34 ± 0.005 mSv/year) **exceeds the value set by regulation by 3 times**. **More contribution U (57,9) following Ra (30.9%)**



First filter: **Katalox light plus**, good efficiency to eliminate Ra.



Second filter: **Hidrofer** has been proved to efficiently remove Ra and U by adsorption.

Selecting the catalyst filter media

- **Tahal**: the feedwater of the Tahal DWTP exceeds the threshold limits for **Fe** concentration established by RD 314/2016, **Mn** is close to the limit and **Ra** isotopes (Ra-228 41.%) are the **main radionuclides** responsible for the ID (59.7%)



First and second filter:

Katalox Light (MnO₂ coated zeolite) because it is efficient in Mn and Ra removal.



Benizalon pilot plant



Tahal pilot plant

Selecting the catalyst filter media

DWTP	1 st filtration stage	2 nd filtration stage
Alboloduy	KATALOX LIGHT WatchWater [®] (Manganese dioxide coated zeolite)	ZEOSORB WatchWater [®] (Zeolite)
Benizalón	KATALOX LIGHT PLUS Watch Water [®] (Manganese dioxide coated dolomite)	HIDROFERChiemiVall [®] (Ferric Hydroxide)
Tahal	KATALOX LIGHT WatchWater [®] (Manganese dioxide coated zeolite)	KATALOX LIGHT WatchWater [®] (Manganese dioxide coated zeolite)

Filter-based pilot plants start-up, validation and operation

Compliance with drinking water quality standards, including radioactivity.

- To **check** the compliance with the drinking water **quality standards** of the treated water
- To **evaluate** the **NORM waste generation** during the operation of the three plants **and the efficiency** of the different strategies applied.

START-UP

- **Daily operation** mode will depend on the **water demand** and **availability by extractions of wells**.
- **Initial operational conditions** has been **established by** bed filtration material **suppliers** (10 m³/h).
- **Choice and dosage of the reagents** (oxidants for regeneration (H₂O₂), acids (HCl) and bases (NaOH/KCl). **Start-up without reagents addition, no pH and ORP control.**
- Initial **regulation backwash operation** in line with rules of the bed-material **supplier**:
 - **Benizalón:** Daily backwash of 8 min (20 m³/h) followed by settling time 2 min
 - **Alboloduy and Tahal:** Daily backwash of 10 min (20 m³/h) followed by settling time 5 min

Results

Water analysis

ALBOLODUY

Filter-based pilot plants start-up, validation and operation

Compliance with drinking water quality standards, including radioactivity.

ALBOLODUY	Radionuclides	Inlet (B)	Outlet (T2)	Removal %	ID INLET mSv/y	ID OUTLET mSv/y	ID REDUCTION %
17/05/2019	U-238 (Bq/l)	0,2160	0,2360	-9,26	0,0158	0,0161	-2,32
	U-234 (Bq/l)	0,2160	0,2290	-6,02			
	Ra-226 (Bq/l)	0,0046	0,0009	80,43			
	Ra-228 (Bq/l)	nd	nd	nd			
11/11/2019	U-238 (Bq/l)	0,204	0,190	6,86	0,0147	0,0138	5,89
	U-234 (Bq/l)	0,204	0,199	2,45			
	Ra-226 (Bq/l)	0,003	0,002	33,33			
	Ra-228 (Bq/l)	nd	nd	nd			

As can be observed, the reduction of U234 and U238 is negligible. Nevertheless, Ra226 shows better behaviour because of the adsorption on the filter material. ORP and pH control turn into critical keys to ensure the coprecipitation of U with Fe and Mn.

TAHAL

Filter-based pilot plants start-up, validation and operation

Compliance with drinking water quality standards, including radioactivity

TAHAL	Radionuclides	Inlet (B)	Outlet (T2)	Removal %	ID INLET mSv/y	ID OUTLET mSv/y	ID REDUCTION %
17/05/2019	U-238 (Bq/l)	0,37	0,24	35,14	0,0916	0,0316	65,47
	U-234 (Bq/l)	0,56	0,36	35,71			
	Ra-226 (Bq/l)	0,091	0,0014	98,46			
	Ra-228 (Bq/l)	0,081	0,021	74,07			
11/11/2019	U-238 (Bq/l)	0,910	0,570	37,36	0,1171	0,0651	44,38
	U-234 (Bq/l)	1,160	0,710	38,79			
	Ra-226 (Bq/l)	0,061	0,019	68,85			
	Ra-228 (Bq/l)	0,066	0,034	48,48			

In this case, good reduction are obtained for both, uranium and radium isotopes. The indicative doses of this water influent is close to the limit. With the treatment safe water is achieved. ORP and pH control turn into critical keys to ensure the coprecipitation of U with Fe and Mn.

BENIZALON

Filter-based pilot plants start-up, validation and operation

Compliance with drinking water quality standards, including radioactivity.

BENIZALON	Radionuclide	Inlet (B)	Outlet (T2)	Removal %	ID INLET mSv/y	ID OUTLET mSv/y	ID REDUCTION %
17/05/2019	U-238 (Bq/l)	2,500	1,500	40,00	0,2923	0,1358	53,54
	U-234 (Bq/l)	3,600	2,100	41,67			
	Ra-226 (Bq/l)	0,090	0,007	92,78			
	Ra-228 (Bq/l)	0,125	0,020	84,00			
			Outlet (T1)				
11/11/2019	U-238 (Bq/l)	0,930	0,600	35,48	0,2053	0,0694	66,18
	U-234 (Bq/l)	1,620	0,940	41,98			
	Ra-226 (Bq/l)	0,177	0,022	87,57			
	Ra-228 (Bq/l)	0,160	0,023	85,63			

In this case, good reduction are obtained for both, uranium and radium isotopes. The indicative doses of this water influent exceed the limit. With the treatment safe water is achieved. ORP and pH control turn into critical keys to ensure the coprecipitation of U with Fe and Mn.

Results

Bed filter materials

Council Directive 2013/59/Euratom

Naturally occurring radionuclides materials

Values for exemption or clearance for naturally occurring radionuclides in solid materials in secular equilibrium with their progeny.

Natural radionuclides from the U-238 series (U234, Ra226 and others)	1 kBq / kg
Natural radionuclides from the Th-232 series (Ra228 and others)	1 kBq / kg

This directive has not yet been transposed to the Spanish legislation

NORM MANAGEMENT

In Spain, the **Order IET/1946/2013 of 17 October**, regulate the management of NORM

Characterization of the NORM wastes:

Radionuclide contents **lower than or equal** to the levels established in table 1 = **managed along conventional routes**.

In the case of **mixture of radionuclides**, the rule of the sum of the quotients between the concentration of the radionuclide present (Ci) and the applicable level (Cli) should be applied so that the following expression is verified:

$$\sum_{i=1,n} C_i / C_{li} \leq 1$$

Table 1. Levels applied to NORM waste in Bq/g, (Annex to the Order IET/1946/2013 of 17 October).

Radionuclide	All materials (Cli)
U-238 (sec) incl. U-235 (sec)	0,5
U natural	5
Th-230	10
Ra-226+	0,5
Pb-210+	5
Po-210	5
U-235 (sec)	1
U-235+	5
Pa-231	5
Ac-227+	1
Th-232 (sec)	0,5
Th-232 (sec)	5
Ra-228+	1
Th-228+	0,5
K-40	5

(sec):radionuclide in secular balance with all its descendants.

(+): radionuclide in secular balance with its short-lived descendants.

Assessment of NORM generation and management opportunities, including filters regeneration.

- To evaluate the NORM waste generation during the operation of the three plants and the efficiency of the different strategies applied.
- To study and evaluate filter cleaning strategies and regeneration with new reagents.

NORM index based on Order IET/1946/2013 of 17 October. Limit value = 1.

	May 2019		November 2019 Before Backwash		November 2019 After Backwash	
	Filter 1	Filter 2	Filter 1	Filter 2	Filter 1	Filter 2
Alboloduy	0,204	0,16	0,298	0,1599	0,29	0,1527
Benizalón	0,99	1,033	0,189*		0,155*	
Tahal	1,388	0,354	8,822*	0,772*	7,996*	0,75*

* NORM index calculated only with Rd 226 and Rd 228 concentrations

Results

Water & Energy consumption

ALCHEMIA PLANTS vs RO PLANTS

ALCHEMIA PLANTS vs RO PLANTS

Data collected between 12/2019 and 01/2020

WATER CONSUMPTION	ALBOLODUY	BENIZALÓN	TAHAL
ALCHEMIA PLANT WATER CONSUMED (m3)	18412,70	553,60	17344,00
ALCHEMIA PLANT DRINKING WATER PROCUCED (m3)	16787,60	466,20	15291,80
REVERSE OSMOSIS PLANT WATER CONSUMED (m3)	60922,46	3812,50	15658,00
REVERSE OSMOSIS PLANT DRINKING WATER PROCUCED (m3)	35420,03	2329,90	10048,60
ALCHEMIA INDICATOR WATER CONSUMED (m3)/DRINKING WATER PROCUCED (m3)	1,10	1,19	1,13
REVERSE OSMOSIS INDICATOR WATER CONSUMED (m3)/DRINKING WATER PRODUCED (m3)	1,72	1,64	1,56
WATER REJECTION REDUCTION	86,5%	70,5%	75,9%

ALCHEMIA PLANTS vs RO PLANTS

Data collected between 12/2019 and 01/2020

ENERGY CONSUMPTION	ALBOLODUY	BENIZALÓN	TAHAL
KWH ALCHEMIA ENERGY CONSUMPTION	4.466,50	316,10	447,50
KWH REVERSE OSMOSIS ENERGY CONSUMPTION	39.702,20	2457,90	12277,60
ALCHEMIA PLANT DRINKING WATER PROCUCED (m3)	16.787,60	466,20	15291,80
REVERSE OSMOSIS PLANT DRINKING WATER PROCUCED (m3)	35.420,03	2329,90	10048,60
ALCHEMIA INDICATOR			
KWH ENERGY CONSUMPTION/DRINKING WATER PROCUCED (m3)	0,27	0,68	0,03
REVERSE OSMOSIS INDICATOR			
KWH ENERGY CONSUMPTION/DRINKING WATER PROCUCED (m3)	1,12	1,05	1,22
Energy consumption reduction	76,2%	35,7%	97,6%

Conclusions and incoming tasks

CONCLUSIONS & NEAR – FUTURE TASKS

The preliminary results regarding radionuclides removal shows that the **plant operation need to be improved by controlling pH and ORP** adding reagents in order **to promote the coprecipitation of uranium with iron and manganese**. However, good behaviour has been observed for radium removal.

Taking into account the **Spanish regulation**, in this moment, **three** of the six **filter** could be considered as **NORM waste**, nevertheless, different conclusion can be achieve when apply the European Directive, in this case only the filter 1 of Tahal plant will be considered as NORM waste with Ra226 and Ra228 concentrations of 2,67 and 2,66 KBq/Kg, respectibely.

The filtration and backwash operation need to be optimized **to promote coprecipitation rather than adsorption** of radionuclides in the filter material in order to **increase the filter's life avoiding turn into NORM waste**.

Regarding the hydraulic operation, a **stable operation** of the plants has been achieved due to the optimal design and construction. In this sense, **high water ($\approx 80\%$) and energy ($\approx 85\%$) savings** compare with RO **have been also demonstrated**.

TOWARDS A SMART & INTEGRAL TREATMENT OF NATURAL RADIOACTIVITY IN WATER PROVISION SERVICES



Thank you very
much for your
attention!!!

Täna teid väga
tähelepanu
eest!!!

Guadalupe Pinna Hernández
Isabel Rodríguez Ruano
F. Javier Martínez Rodríguez
José L Casas López

